

# Liquefied Petroleum Gas (LPG)

# Storage of LPG Cylinders

- According to the Gas Safety Ordinance, unless specifically approved by the Gas Authority, storing liquefied petroleum gas (LPG) cylinders (including empty cylinders) with a total nominal water capacity of over 130 litres is prohibited.
- According to the Code of Practice GU06, it is recommended not to use LPG cylinders for catering purposes in commercial premises if town gas or a central LPG supply system is available.

# Brand & Colour of LPG Cylinders

- Blue (Shell)
- Red (Mobil)
- Orange (Concord)
- Yellow (Sinopec)
- Light Blue (Esso)
- Green (NewOcean)




# LPG Cartridges



# Common Sizes of LPG Cylinder

Nominal Water Capacity of LPG Cylinder (Litre)	Permitted No. of Cylinder
0.55 (LPG cartridge)	236
23.5	5
26.2	4
35.5	3
49.5	2

# Information on Cylinder Body



Serial number

Water capacity

Design pressure

# Enhancing Gas Safety



- It is desirable to purchase and use domestic gas appliances (bearing a GU mark) approved by EMSD (e.g. cassette cookers).
- Installation, testing, replacement and maintenance of gas appliances must be carried out by registered gas installers employed by registered gas contractors.



# Enhancing Gas Safety

---

- LPG cylinders should be purchased from LPG distributors approved by registered gas supply companies.
- To ensure safety, customers should arrange for the gas installations and appliances in commercial premises to be maintained regularly and inspected annually.



# End

